

CITY OF NEWTON, MASSACHUSETTS

PURCHASING DEPARTMENT

purchasing@newtonma.gov

Fax (617) 796-1227

July 11, 2012

ADDENDUM #2

INVITATION FOR BID #12-97

WARD SCHOOL EXTERIOR MASONRY & RELATED REPAIRS

THIS ADDENDUM IS TO: **Revised Answers to the Questions on Addendum #1:**

Q1. Have the Boiler Room steel window sash and frame been checked for lead paint, or caulking that may contain lead?

A1. It should be assumed that this sash and frame contain lead, as well as the caulking and should be handled as if it does contain lead.

Q2. What should be done with plant growth adjacent to the building; it obstructs access to the exterior walls of the building.

A2. For bidding purposes, assume that all plant materials next to the exterior walls may be trimmed by the G.C. down to the minimum required to expose all affected wall surfaces in the scope of work.

All other terms and conditions of this bid remain unchanged.

PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM.

Thank you.

Purchasing Department

CITY OF NEWTON, MASSACHUSETTS

PURCHASING DEPARTMENT

purchasing@newtonma.gov

Fax (617) 796-1227

July 11, 2012

ADDENDUM #1

INVITATION FOR BID #12-97

WARD SCHOOL EXTERIOR MASONRY & RELATED REPAIRS

THIS ADDENDUM IS TO: **Answer the following Questions:**

Q1. Have the Boiler Room steel window sash and frame been checked for lead paint, or caulking that may contain lead?

A1. No, this particular window has not been checked for hazardous materials. The City of Newton will separately contract to test the window unit for lead-containing materials.

Q2. What should be done with plant growth adjacent to the building; it obstructs access to the exterior walls of the building.

A2. The City will check for any plant materials that need to remain. For bidding purposes, assume that all plant materials next to the exterior walls may be removed by the G.C. down to grade to expose all affected wall surfaces in the scope of work, at the beginning of the project.

All other terms and conditions of this bid remain unchanged.

PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM.

Thank you.

Purchasing Department